

AMENDMENT 6

**Invitation For Bids (IFB)
UOG IFB No. B26-08**

Date Issued: February 24, 2026

“INTERNAL NETWORK INSTALLATION FOR THE SCHOOL OF ENGINEERING”

This is to notify all prospective offerors of the following amendment set forth below:

1. **DEADLINE FOR WRITTEN QUESTIONS/CLARIFICATIONS should read as follows:**
The last day for UOG to accept WRITTEN QUESTIONS and/or CLARIFICATIONS is seven (7) business days BEFORE the bid submission deadline Tuesday, March 03, 2026.
2. **DEADLINE FOR SUBMISSION of Bid Packages should read as follows:**
Thursday, March 12, 2026., ON or BEFORE 2:00 P.M. Chamoru Standard Time, via link provided for electronic submission to Bid Share folder provided by UOG Procurement Office. One (1) original copy along with original bid security must be dropped off to Procurement Office before bid submission deadline.
3. **Question and Answer Sheet 2 set forth as attached.**
4. **Question and Answer Sheet 3 set forth as attached.**
5. **2nd Site Visit Meeting Minutes**
6. **UOG SENG MAP – Data Rough In set forth as attached.**
7. **Clarification to Amendment 1 – Question #2 (see revision in red):**

Question 2: Copper Cabling

2.1. How many CAT6A cables are required for each data drop?

UOG: ~~One (1)~~

Bidders should follow the numbers found on the drop map provided

2.2 How many CAT6A cables are required for each Wireless Access Point?

UOG: One (1)

2.3. How many CAT6A cables are required for each security camera?

UOG: One (1)



ADMINISTRATION & FINANCE
Consolidated Procurement Office

All other terms and conditions remain the same.

A handwritten signature in blue ink, appearing to read 'Damian Guerrero', written over a horizontal line.

Damian Guerrero
Procurement Manager

Please acknowledge receipt and return by email to uog.bids@triton.uog.edu:

Name of company: _____

Print Name/Signature/Date

T: +1 671.735.2925 F: +1 671.735.3010 W: www.uog.edu E: uog.bids@triton.uog.edu

Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96913

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.

QUESTION & ANSWER SHEET NO.2

February 24, 2026

*In response to the written “Questions” and/or ‘Request for Clarifications’ UOG received as of February 11, 2026
@ 3:08 pm from vendor: **DOCOMO PACIFIC***

1. To ensure we allocate the right resources and maintain your project timeline, could you advise whether installer certification is a strict requirement, or if validated and certified cabling test results will meet your acceptance criteria?

UOG: Licensed installer(s) is/are required to be on-site to ensure proper installation. It is the responsibility of the contractor to ensure all cable warranty requirements are met with proper installation and certified installers.

2. If installer certification is a strict requirement, what certifications will be accepted?

UOG: BICSI, CNCI, DCIC, or manufacturer-specific certification on the products installed.

3. Can you confirm whether Category 6 cabling may be proposed as an alternative, or if only Category 6A solutions will be accepted?

UOG: UOG will accept Category 6 cabling

4. Is this an all or Nothing?

UOG: YES

5. If needed, can Docomo conduct a resurvey of the job site prior to submission?

UOG: There was a 2nd site visit held on February 20, 2026.

6. 2.4 - Contractor shall furnish and install network cable management solutions for network cabinets to ensure a neat and tidy network cabinet. - How is many needed?

UOG: This would be based on the proposed network cabinet configuration. For guidance, cable management will be required for every patch panel that is installed.

7. 5.1.2. A minimum of one 220v electrical outlets and two 110v 30 amps electrical outlets shall be installed at no more than 3 feet from IDFs and MDF network rack or as designated by UOG. – Would Docomo be responsible for this as part of this bid if awarded?

UOG: UOG is not designating any electrical outlets for this project. Vendor will not be responsible for this as part of this bid if awarded.

QUESTION & ANSWER SHEET NO.3

February 24, 2026

*In response to the written “Questions” and/or “Request for Clarifications” UOG received as of February 11, 2026 @ 3:29 pm from vendor: **PACIFIC DATA SYSTEM***

1. Please confirm whether core drilling through concrete walls is allowed when required to complete the necessary cable pathways.

UOG: 3-inch wall penetration is acceptable, provided that a pachometer is used to locate the rebar and conduits and that these are not disturbed

2. Can UOG provide a clean floor plan (Visio or PDF) without the new IMO drop count indicators (blue squares) to support accurate takeoffs and identify where the original IMO drop locations are?

UOG: Please see attached.

3. Can UOG provide redline drawings or shop drawings that show the telecom (data/voice) conduit routes, conduit sizes, and any associated junction or pull boxes for this project?

UOG: Please see attached.

4. Please confirm whether there are any country-of-origin requirements or restrictions for materials to be supplied under this project.

UOG: UOG requires products be BABA compliant or TAA compliant.

5. Will UOG allow the use of existing telecom conduits that currently contain CAT6A cabling installed and terminated by the contractor? Our plan is to disconnect the conduit at the nearest coupler (if available), pull additional CAT6A cable, and drop it on the requested side of the room. The existing cable will remain in place.

UOG: The University of Guam will allow the use of existing telecom conduits for the purpose of installing additional CAT6 cable. Contractors may disconnect the conduit at the nearest coupler, where accessible, to facilitate the pull of new cabling.

However, please note the following requirements:

- a. **Protection of Existing Infrastructure**

Any existing cabling within the conduit must remain intact and undamaged. The contractor assumes full responsibility for ensuring that no degradation, stretching, crushing, or performance impact occurs to existing cables during the installation process.

“INTERNAL NETWORK INSTALLATION FOR THE SCHOOL OF ENGINEERING”

b. Testing and Certification Requirement

To ensure that the existing cabling is not affected in the course of work, the contractor is required to:

- Perform full certification testing of the impacted cable runs to confirm they still meet CAT6 performance standards.
- Repair or replace any existing cabling found to be damaged or performing below standard due to the contractor’s activities.
- Provide test results and certification documentation as part of the project close-out package.

c. Documentation

All test results for any affected existing cabling must be submitted to UOG for review and acceptance prior to final approval of work.

6. Please provide the anticipated project timeline, including any key milestones or required completion dates.

UOG: The School of Engineering is officially opened and hosting classes and office. Since the facility is already being utilized for daily operations, it is important that the cabling installation be completed as soon as possible. UOG is looking to have the installation completed no later than end of May/early June.

UOG IFB B26-08
INTERNAL WIRING INSTALLATION FOR THE SCHOOL OF ENGINEERING
2nd non-mandatory Pre-bid Conference & Site Visit
February 20, 2026, at 2:00 pm

UOG Representatives:

Vince Dela Cruz – Chief Information Officer
Arty Rengulbai – IT Support Technician
Andrew Guihama – MicroComputer Specialist
Damian Guerrero – Procurement Manager
Yosko Alafonso – Buyer II
Jonathan Nguyen – SENG

Attendees:

Future World
Corporation:
• Arnold
Felizardo

Compacific:
• Kevin Tagey

L&K Communication:
• Kevin
Navarro
• Ejay
Mendiola

Docomo:
• Derek
Quichocho
• Robin Carlos

Calpac:
• Lex
Monis
• Jeff
Andaw

The location of the pre-bid conference & site visit was at the School of Engineering. Attendees were asked to sign in. Yosko explained that the meeting will not be recorded but photographed instead and was called to order at 2:10 pm. After the introductions of everyone attending, she explained a few housekeeping notes:

- All questions and answers are not official unless officially communicated through the procurement office via uog.bids@triton.uog.edu
- Not accepting alternate bids
- Deadline for submissions will be extended to March 12, 2026, on or before 2 pm.

UOG is looking to install internal network cabling and Wireless Access Points in the School of Engineering Building. The cabling needs to be structured, scalable, and easy to maintain. The goals of this project are:

1. Install new network cabling infrastructure to a minimum of Category 6A
2. Install cabling infrastructure to allow for ease of scalability
3. Install cabling infrastructure to simplify maintenance and troubleshooting
4. Document the raceway and pathways of the upgraded cabling infrastructure
5. Install and mount UOG provided Wireless Access Points

This site visit is a follow up request and allowed the vendors this time to look more closely at all the rooms in SENG.















T: +1 671.735.2925 F: +1 671.735.3010 W: www.uog.edu E: procurement@triton.uog.edu
Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.




Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.




Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



T: +1 671.735.2925 F: +1 671.735.3010 W: www.uog.edu E: procurement@triton.uog.edu
Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.



T: +1 671.735.2925 F: +1 671.735.3010 W: www.uog.edu E: procurement@triton.uog.edu
Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.

INVITATION FOR BID (IFB) REGISTER

**"UOG IFB B26-08 : INTERNAL WIRING INSTALLATION FOR THE SCHOOL OF ENGINEERING"
PRE-BID CONFERENCE / SITE VISIT SIGN IN SHEET**

DATE PUBLISHED: Tuesday, January 13, 2026

AMENDMENT# / DATE ISSUED: Amendment 1: 1/26/2026
Amendment 2: 1/28/2026
Amendment 3: 02/06/2026

Amendment 4: 02/11/2026
Amendment 5: 02/17/2026

PAID #	COMPANY NAME	FULL NAME	SIGNATURE	TIME	PHONE NUMBER/ FAX NUMBER
1	FUTURE WORLD	ARNOLD FELIZARDE	[Signature]	1:48	
2	COMPACTIC	Kevin Tagay	[Signature]	1:52	
3	L&K COMMS	Kevin Navarro	[Signature]	1:53	
4	L&K COMMS	Ejey M	[Signature]	1:54	
5	COMPACTIC COMPACTIC	SARON FERMUNDO	[Signature]	1:54	
6	DOLIVO	ANGRES PARRAS	[Signature]	1:58	
7	DOLIVO	DENEKELICHON	[Signature]	1:05	
8	CALPAC	LEX MONIS	[Signature]	2:20	
9	CALPAC	JEFF ANDAW	[Signature]	2:21	
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					