

**AMENDMENT 4**

**Invitation for Bid (IFB)  
UOG IFB No. B21-21**

Date Issued: August 31, 2021

**PURCHASE & INSTALLATION OF A NEW 600K GENERATOR TO SUPPORT UOG'S COMPUTER  
CENTER - MARC – LIBRARY FACILITIES**

This is to notify all prospective offerors of the following amendment set forth below:

- 1.1 Question & Answer Sheet 4 as set forth in the attached.**
- 1.2 Please note LAST DAY for additional questions/clarifications has been extended to Friday, September 10, 2021.**
- 1.3 Deadline for submission should read as follows: Friday, September 17, 2021 at 2:00 p.m. (your bid submission must be submitted electronically to the Bid Share folder provided by UOG Procurement Office on or before 2:00 p.m.) Bid opening will take place at 3:00 p.m. via ZOOM link provided by procurement office to all registered offerors.**

All other terms and conditions remain the same.



Emily G. Gumataotao  
Supply Management Administrator

---

Please acknowledge receipt and email: **uog.bids@triton.uog.edu**:

Name of company: \_\_\_\_\_

---

Print Name/Signature/date

T: +1 671.735.2925 F: +1 671.735-3010 W: [www.uog.edu](http://www.uog.edu) E: [uog.bids@triton.uog.edu](mailto:uog.bids@triton.uog.edu)

Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96913

*The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.*

**QUESTION & ANSWER SHEET NO. 4**  
**August 31, 2021**

*In response to the written "Questions" received on August 30, 2021 @ 2:34pm from vendor: **LMS IMPORTS GUAM***

**Question 1:** With regards to the UOG ISO ("DIESEL GENERATOR SET STATIONARY 600KW, WITH AUXILIARIES" is ISO 8528) requirement, If the genset submitted has manufacturer's documentation verifying compliance with **ISO 8528** rather than actual ISO Certification, Will UOG accept the manufactured Generator ? The Generator manufacturer has over 30 years of experience in manufacturing Generators in USA and is ETL certified to UL 2200.

**Answer:** ***Please refer to Amendment 3, Q&A Sheet No.3, and Question 1.***

**Question 2:** There is a huge shortage of Raw Materials in the USA Mainland, every manufacturer we have corresponded with states that the production of Generator take 18-20 weeks even with expedited production fee. Considering this impact, we request to extend the POP from 120 days to 270 days which includes the installation and commissioning of the Generator.

**Answer:** ***UOG confirms delivery time extended from 120 days to 240 days.***