

AMENDMENT 1

**Invitation For Bids (IFB)
UOG IFB No. B26-06**

Date Issued: January 26, 2026

"FIBER OPTIC OS2 NETWORK CABLING INSTALLATION FOR WERI AND SCHOOL OF HEALTH"

This is to notify all prospective offerors of the following amendment set forth below:

1. DEADLINE FOR WRITTEN QUESTIONS/CLARIFICATIONS should read as follows:

"The last day for UOG to accept WRITTEN QUESTIONS and/or CLARIFICATIONS is five (5) business days BEFORE the bid submission deadline Monday, February 09, 2026."

2. DEADLINE FOR SUBMISSION of Bid Packages should read as follows:

"Monday, February 16, 2026., ON or BEFORE 2:00 P.M. Chamoru Standard Time, via link provided for electronic submission to Bid Share folder provided by UOG Procurement Office. One (1) original copy along with original bid security must be dropped off to Procurement Office before bid submission deadline."

3. Question & Answer Sheet 1

All other terms and conditions remain the same.



Damian Guerrero
Procurement Manager

Please acknowledge receipt and return by email to uog.bids@triton.uog.edu:

Name of company: _____

Print Name/Signature/date

T: +1 671.735.2925 F: +1 671.735.3010 W: www.uog.edu E: uog.bids@triton.uog.edu

Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96913

*The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges
Senior College and University Commission and is an equal opportunity provider and employer.*

QUESTION & ANSWER SHEET NO.1

January 26, 2026

*In response to the written "Questions" and/or 'Request for Clarifications' UOG received as of January 22, 2026
@ 4:41 pm from vendor: Pacific Data Systems*

Question 1: Ref Page 31 of 37 2.2.1 and 2.2.2

a. Confirm which type of conduit and size is to be used for outside trenching

UOG: No outside trenching is required for this project

b. Confirm which type of conduit and size is to be used for FO cable runs inside the building.

UOG: minimum 2" diameter conduit (Schedule 40 PVC or equivalent) where needed.

c. Confirm if 4way, 12 mm duct microduct conduit is acceptable for inside and outside applications with EMT conduit for exposed areas entering the buildings.

UOG: Yes

Question 2: Ref page 32 of 37 2.3, Please confirm if armored FO cable is to be run the entire length of the route?

UOG: Armored cable or equivalent for underground runs or where additional protection is required. Armored cables are not required for inside building runs. No breaks or splices in installation.

Question 3: Define timeline for the performance of the project.

UOG: Four weeks upon receipt of notice to proceed.

Question 4: Confirm that all work is to be performed on property controlled by UOG and will not require any DPW, GEPA, or other GovGuam permitting.

UOG: Confirming that all work is to be performed on property controlled by UOG and will not require any DPW, GEPA or other GovGuam permitting required for trenching.