

AMENDMENT 6

**REQUEST FOR PROPOSALS
UOG RFP No. P22-02**

Date Issued: May 6, 2022

“DESIGN BUILD CONSTRUCTION SERVICES FOR A NEW SCHOOL OF ENGINEERING”

This is to notify all prospective offerors of the following amendment set forth below:

1.1 Question & Answer Sheet 4 set forth in the attached.

All other terms and conditions remain the same.



Emily G. Gumataotao
Supply Management Administrator

Please acknowledge receipt and return by email to uog.bids@triton.uog.edu:

Name of company: _____

Print Name/Signature/date

QUESTION & ANSWER SHEET 4

May 6, 2022

FROM: Emily G. Gumataotao, Supply Management Administrator

RE: UOG-RFP-P22-02 - New School of Engineering Building

VENDOR: Orion Construction Corporation, dated, 05/04/2022

Q 1.) ... if a sprinkler system is required for the project

Q1

Question or Clarification:

Clarification #01: Based on Amendment #05 dated May 2, 2022, Question or clarification from vendor dated 04/14/2022 "stated it is their understanding that an automatic sprinkler system will be required"

The RFP requires Fire Protection which is not specific to an automatic sprinkler system alone.

We would like to clarify and confirm from UOG if sprinkler system is required in this project.

A 1.) Yes, a fire sprinkler system is required and must meet Guam Fire Code.